

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by DR. Nagendra Yadav (Medical officer)
(Name of Officers with designation) from Ayaz PHED inspected the
P.B. R.P. Academy Jaswantpur Muradganj (Name & Address of the school) on
12-09-2026 (date of inspection) and on the basis of Water Test Report (Attached)
bearing no NR/2026/09/80 dated 15/09/2026 of UP Jal Nigam Mirauli
(PHED Lab) certified that the P.B. R.P. Academy Jaswantpur Muradganj (Name of school) has
safe drinking water facilities for the students and members of staff of the institution. School is also
maintains the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central/State/ U.T. Govt.

This certificate is valid till 11-09-2027.

To

P.B. R.P. Academy Jaswantpur
Muradganj Auraiya
(Name & Address of the Institution)

Signature with Seal:

Name

: DR. Nagendra Yadav

Designation

: Medical officer (Ayaz)

Name & Address of the Office / Department:





Office of Executive Engineer , Khand
Karyalay
Up Jal Nigam (Rural) .Mihauli , Auraiya

Issue No.: 00

Issue Date: 17.10.2024

Revision No.:00

Revision Date :00

Test Report Water

Report No.	AUR/2026/09/80	Date	15.09.2026	Page No	80
Customer Details					
Office Name & Address	PBRP ACADEMY ,JASWANTPUR ,AURAIYA				
Ref. Letter No. & Date	11.09.2026				
Basic Details of Sample					
District	AURAIYA	Block	AURAIYA		
Gram & Nagar Panchayat	JASWANTPUR	Village/City	JASWANTPUR		
Habitation	JASWANTPUR	Location	JASWANTPUR		
Water Source	SUBMERSABLE PUMP	Sample No	Aur/11/09/07		
Quantity of Sample	1 lit	Date of S.C	11.09.2026		
Receiving Date	11.09.2026	S. Collector	MR. Ashutosh Tripathi		
Sample Depositor	MR. Ashutosh Tripathi				
Analysis Start Date	11.09.2026	Analysis Completion Date	14.09.2026		
Environmental Condition					
Temperature	25±3°C	Humidity	50±15%		
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Taste	Agreeable	Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 2023
2	Odour	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2023
3	Colour	10	5	15	IS 3025 (Part 4): 2021(Platinum Cohalt Visual Comparison Method)
4	Turbidity (NTU)	1.30	1	5	IS3025(Part :0) :2023 (Nephelometric method)
5	PH	7.11	6.5	8.5	IS3025(Part11) :2022 (Electrometric Method)
6	TDS (Mg/L)	698	500	2000	IS3025 (Part 16):2023 Gravimetric Method
7	Alkalinity (Mg/L)	580	200	600	IS3025(Part-23) :2023 (Titration Method)
8	Total Hardness (Mg/L)	400	200	600	IS3025(Part-21) :2019 (Titration Method)
9	Sulphate (Mg/L)	19.89	200	400	APHA 23 RD Ed 2017, 4500-SO ₄ (E. Turbidimetric Method) 2023
10	Nitrate (Mg/L)	1.20	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method) 2023
11	Fluoride (Mg/L)	1.02	1.0	1.5	APH 23 RD Ed 2017, 4500-F (C. Ion Selection Electrode Method) 2023
12	Iron Mg/L)	0.11	0.3	1.0	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method) 2023
13	Chloride Mg/L)	22	250	1000	IS3025(Part-32) : 2019 (Titration Method)
14	Calcium (as Mg), Mg/l	120	75	200	IS 3025 (Part 40): 2023
15	Magnesium (as Mg), Mg/l	68.05	30	100	IS3025(Part-46) : 2023
*These Parameters are out of NABL Scope, BDL- Below Detection Limit, NT- Not Tested					
Note	1-This Certificate refers only to the particular sample (s) submitted for testing.				
	2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory				
	3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.				
	4-Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.				
	5-Parameters above permissible limit are written in Bold.				
Prepared by Analyst Quality/Technical Manager Deputy Quality Manager Laboratory Contact Details/Email-					
U.P.J.N. Auraiya					

